



SECTION A-A

PLANTER

NOTES:

1. PROVIDE PROTECTION FROM ALL VEHICLE TRAFFIC, EQUIPMENT STAGING, AND FOOT TRAFFIC PRIOR TO, DURING AND AFTER CONSTRUCTION.
2. DIMENSIONS:
 - TOP OF GROWING MEDIUM TO OVERFLOW ELEVATION SHALL BE A MINIMUM OF 12".
 - TOP OF SIDEWALK ELEVATION ADJACENT TO PLANTER SHALL BE NO LESS THAN 3" ABOVE GUTTER ELEVATION.
 - TOP OF SIDEWALK ELEVATION ADJACENT TO PLANTER SHALL BE NO GREATER THAN 22" FROM TOP OF PLANTER GROWTH MEDIUM.
3. PIPING:
 - PIPE SHALL BE PVC D3034 SDR 35, 6" MINIMUM DIAMETER WITHIN PLANTER. PIPING MUST HAVE 1% SLOPE, BOTTOM OF PIPE SHALL BE SET AT 9" ABOVE EXISTING SUBGRADE.
 - OVERFLOW SHALL BE PIPED TO A STANDARD CURB INLET/CATCH BASIN STRUCTURE OR STORM MANHOLE, SEE DRAWING 619.
4. GROWING MEDIUM: SEE APPENDIX A OF STORMWATER MANUAL FOR SPECIFICATION.
5. VEGETATION: REFER TO PLANTING REQUIREMENTS IN APPENDIX A OF STORMWATER MANUAL, SEE DRAWING 630 FOR PLANT SPACING REQUIREMENTS.
6. WATERTIGHT LINER (SEE DRAWING 625 FOR LINER ATTACHMENT REQUIREMENTS):
 - WHEN WITHIN CONTAMINATED SOIL OR 10' OF STRUCTURE FOUNDATION OR PAVED STRUCTURAL SECTION OR UNDERGROUND STRUCTURES, BOTTOM OF FACILITY MUST BE LINED WITH A WATERTIGHT LINER.
 - LINER SHALL BE 30 MIL HDPE OR APPROVED EQUAL.
 - LINER SHALL BE PLACED AROUND ENTIRE PERIMETER OF FACILITY.
 - LINER REQUIRED UNLESS FACILITY'S BOTTOM AND SIDES ARE MONOLITHIC CONCRETE.
7. CHECK DAMS:
 - REINFORCED CONCRETE CHECK DAMS SHALL BE PLACED AT LEAST EVERY 30 FEET.
8. MINIMUM PLANTER WALL HEIGHT OF 34".



SCALE	NTS		
DATE	JUL '25	REV.	1
ENGR.	DW	DRAWN	KAE
DRAWING NO. 621			