



## Addendum 5: Outdoor Lighting

### Type I Minor Site Plan & Design Review

Changes to outdoor lighting must comply with OCMC Sections **17.62.065**.

Provide details of any poles, fixture height and design, lamp type, wattage and spacing of lights. Manufacturer Cut Sheets are acceptable provide they accurately reflect the lighting type proposed. \_\_\_\_\_

Have lighting fixture details been provided? ☐ Yes ☐ No

Has an exterior lighting plan been provided? ☐ Yes ☐ No

### 5.1 Lighting Levels

| Requirements:  | Check if YES | Check if NO | Check if No Change Proposed | Staff Confirmation |
|--|--------------|-------------|-----------------------------|--------------------|
| Glare shall not cause illumination on other properties in excess of a measurement of 0.5 footcandles of light as measured at the property line.  |              |             |                             |                    |
| Lighting shall be provided in parking lots and vehicular circulation areas.  |              |             |                             |                    |
| Lighting shall be provided in pedestrian walkways, pedestrian plazas, and pedestrian circulation areas.  |              |             |                             |                    |
| Lighting shall be provided at all building entrances. Main building entrances shall be well lighted and visible from any transit street. The minimum lighting level for building entries fronting on a transit street shall be three foot-candles.   |              |             |                             |                    |
| With the exception of pedestrian scale lighting, all light sources shall be concealed or shielded with a full cut-off style fixture  |              |             |                             |                    |
| The maximum height of any lighting pole serving a multi-family residential use shall be 20 feet. The maximum height serving any other type of use shall be 25 feet, except in parking lots larger than 5 acres, the maximum height shall be 35 feet if the pole is located at least 100 feet from any residential use. Lighting for outdoor recreational uses such as ball fields, playing fields, tennis courts, and similar uses are allowed a pole height of 80 feet. |              |             |                             |                    |
| Floodlights shall not be utilized to light all or any portion of a building facade between 10 p.m. and 6 a.m.  |              |             |                             |                    |

|   |  |  |  |  |
|---|--|--|--|--|
| Lighting on outdoor canopies shall be fully recessed into the canopy and shall not protrude downward beyond the ceiling of the canopy.  |  |  |  |  |
| All outdoor light not necessary for security purposes shall be reduced, activated by motion sensor detectors, or turned off during non-operating hours.   |  |  |  |  |
| Light fixtures used to illuminate flags, statues, or any other objects mounted on a pole, pedestal, or platform shall use a narrow cone beam of light that will not extend beyond the illuminated object. |  |  |  |  |
| For upward-directed architectural, landscape, and decorative lighting, direct light emissions shall not be visible above the building roofline.   |  |  |  |  |
| No flickering or flashing lights shall be permitted, except for temporary decorative seasonal lighting.   |  |  |  |  |

Note: There may be more information required once your application has been reviewed.